

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1496:151 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100

DESIGN: Models FRSSP-2415W, FRSSP-241575W, FRSSP-2430W, FRSSP-2475W, FRSSP-24110W, FRSSP-1215W, FRSSP-121575W, FRSSP-2415C, FRSSP-2430C, FRSSP-2475C, and FRSSP-24100C synchronized Strobe Lights. Model number may be followed by any two alpha/numeric characters indicating lens orientation, lettering and color. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

Electrical	20-31 VDC/FWR
Candela	15= 15cd, 1575= 15/75cd on axis, 30= 30cd, 75= 75cd, 100= 100cd (Wall)
Flash rate	60 Flashes/minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Models with W are intended for wall mount only. Models with C are intended for ceiling mount only.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as strobe light suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only. For synchronization strobes, Models FSM-12/24 or FDSM-12/24 Sync Control Module (CSFM Listing No. 7300-1496:103) must be used.

03-10-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 22, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**